

Public Address Systems

To facilitate this ambition of getting the quality right, these checks should take place:

- Ensure audibility and annunciation testing is completed to customer's acceptance
- Is a (PA/VA) voice alarm specified as part of the fire strategy? If so ensure the system is designed and installed to BS 5839. (The standards for voice alarm systems are more onerous than for standard public address systems)
- Ensure any interface requirements with AV systems are addressed.

Our Quality vision:

We will get it right first time on all our projects
by delivering exceptional customer service

